



SMARTLINE A200 WM

Exit luminaire in compliance with EN 60598-1/2-22 and EN 1838.

Flat, architecturally attractive die-cast aluminum housing. Screwless, easy-to-use locking mechanism.



Versions for wall mounting with 10 mm light deflecting pane and interchangeable pictograms. The luminaire price includes one pictogram foil set - arrow left/right/down/up/blind (Visibility distance [!- C:patr7816506926379@This@class18521058581515
The luminaire is available with a 1 or 2 Watt LED-bar.

Technical specifications

Luminaire type	Luminaires for central battery systems		Self contained luminaires	
Illuminant	1 W LED-bar	2 W LED-bar	1 W LED-bar	2 W LED-bar
Visibility distance	23 m			
Connecting terminals	3 x 2.5 mm² for double assignment			
Colour	white			
Material	Aluminum die-cast			
Mounting type	Wall mounting			
Dimensions (W x H x D)	WM 274 x 210 x 37 mm			
Pane dimensions (W x H x D)	248 x 148 x 10 mm			
Protection class	IP40			
Safety class	I			
IK Safety class	IK03			
Light current (mains)	130 lm	260 lm	130 lm	260 lm
Luminous flux				
Emergency (DC) / mains				
Battery duration 1h	–	–	50% / 100%	30% / 100%
Battery duration 3h	–	–	50% / 100%	30% / 100%
Battery duration 8h	–	–	25% / 100%	15% / 100%
Power consumption	4.5 VA	5.5 VA	4.5 VA	5.5 VA
Battery current input	11 mA	14 mA	–	
Battery duration	–		1h / 3h / 8h	
Battery operation				
Voltage supply	230V 50/60Hz; 220V DC +25/-20%		230V 50/60Hz	
NiMH-battery				
Battery duration 1h	–	–	4,8V 0,8Ah	4,8V 0,8Ah
Battery duration 3h	–	–	4,8V 0,8Ah	4,8V 0,8Ah
Battery duration 8h	–	–	4,8V 0,8Ah	4,8V 0,8Ah
Temperature range	-10°C to +40°C		–	
Non-maintained mode	–		0°C to +35°C	
Maintained mode	–		-5°C to +30°C	
optional				
Multi-switch and monitoring module	DALI ELC MSÜ3 SET009 SET010		–	
Self monitoring	–		SELF CHECK	
Central monitoring	–		SAFELOG Line	
Wireless monitoring	–		SAFELOG Wireless	



Wall mounting



Pictogram-set - included in the delivery



Optional pictograms (-sets)



Accessories

Wire guard
Pictograms